

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRSUBD20232899  
Address: 2840 SE BLUE PKWY, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:                    | Inspector:    | Outcome: | Date:                       |
|--------------------------------|---------------|----------|-----------------------------|
| <b>Sanitary Sewer - Vacuum</b> | Bobby Richest | Partial  | Thursday, February 27, 2025 |

Informational:

1 Misc

12/13/24 Friday JMJ (Selby)  
MH-A10 passed around 12:00PM.  
MH-A9 passed @ 1:35PM.

12/17/24 Tuesday JMJ (Selby Construction)  
MH-A8 passed on 12/16/24 Monday.

12/18/24 Wednesday JMJ (Selby Construction)  
MH-A7 passed on 12/17/24 Tuesday.

2-26-25 BR Contractor (Selby Excavation) preformed vacuum test on MH B-2 passed. MH B-1 failed.

2-27-25 BR Contractor (Selby Excavation) preformed vacuum test on MH B-1 passed.

**Comments:**