

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20245503
Address: 2619 SW BARLEY FIELD DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---|----------------|----------|--------------------------------|
| Erosion Control Inspection Residential | Dustin Agcopra | Partial | Thursday, February 27, 2025 |

Informational:

| | | |
|---|-----------------------------|--|
| 1 | Miscellaneous Correction | Erosion control is in place and must be properly maintained until CofO |
|---|-----------------------------|--|

Corrective Action Required:

| | | |
|---|----------------------------|--|
| 2 | DCM3 ESC REQUIRED 2 DAY | 2-24-25 Dustin A, Silt fence is down, Street needs cleaned of mud and gravel. EROSION CONTROL REQUIRED. EROSION CONTROL SHALL BE IN COMPLIANCE WITHIN TWO BUSINESS DAYS. 2-26-25 Dustin A, Silt fence still down. Remove restroom from stormbox 2-27-25 Dustin A, Silt fence is back up, restroom removed from storm box. Must maintain erosion control until vegetation is established |
|---|----------------------------|--|

Comments: