

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20230994  
Address: 1021 SE HAMBLER RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Erosion Control Inspection Residential</b>	Bobby Richest	Partial	Thursday, January 02, 2025

Informational:

1 Misc

-Install gravel filter at site entrance and clean mud from streets. No further inspections will be performed until in compliance

1-2-25 BR Contractor installed gravel on south entrance of site and clean up mud off street.

2-3-25 BR Erosion control is up and working order.

2-17-25 BR Erosion control is up and working order.

2-28-25 BR Silt fence has several cut and rips in silt fence around inter property. Need to repair silt fence.

**Comments:**