## CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200 **DEVSERVICES.CITYOFLS.NET**

## **Inspection Summary**

Permit #:PRRES20244023Address:2748 SW 11TH TER, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Driveway Inspection	Devon Perry	Partial	Tuesday, February 25, 2025
Informational:			
1 Misc	2-25-25 DP. Crew had dw formed, aggregate compacted. Told contractor to keep cross slope though out approach with sidewalk not formed up yet. Approved to pour.		

Comments: