

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20244370  
Address: 1042 SW FIORD DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Sidewalk Inspection</b>	Devon Perry	Partial	Friday, February 28, 2025

Informational:  
1 Misc 2-28-25 DP. PARTIAL SW INSPECTION. SW on the East side of the DW approach was formed, aggregate compacted while I was onsite, cross slopes were in compliance. Approved to pour.

**Comments:**