

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20226232
Address: 120 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Miscellaneous Inspection	Robb Popp	Partial	Friday, February 28, 2025

Corrective Action Required:

1	Misc	**Pre final walkthrough for phase 1, renovations, partial only:
---	------	---

206-GFCI by sink
204-GFCI by sink
2E-232- not ready
Install fire door at storage
Rate penetration at cable tray in 200a
2e-121 incomplete
2E-120 not ready
Exam rooms not ready
**OK to bring in equipment and furniture

Comments: