

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20232899
Address: 2840 SE BLUE PKWY, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sanitary Sewer - Air Test	Bobby Richest	Partial	Monday, March 03, 2025

Informational:

1	Misc	2-26-25 BR Contractor (Selby Excavation) preformed air test on 24" PVC pipe between MH B-1 to MH B-2 passed.
		3-3-25 BR Contractor (Selby Excavation) preformed air test on 24" PVC between MH B-2 to MH B-3 passed.

Comments: