

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20241801
Address: 2203 SW HOOK FARM DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Failed	Monday, March 03, 2025

Corrective Action Required:

1 Misc

- provide as graded plot plan
- final grade and sod
- splash blocks and sump pump discharge to extend 36" from foundation
- obtain issued lawn irrigation permit
- paint gas line under deck

Comments: