## CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

## **DEVSERVICES.CITYOFLS.NET**

## **Inspection Summary**

Permit #: PRRES20243932

Address: 3441 SE CORBIN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date:

Occupancy Inspection - Codes Kyle Beard Failed Monday, March 03,

Residential 2025

Corrective Action Required:

1 Miscellaneous -Hand and guard rails are required at the front porch

Correction -Seal exterior garage lights

-Garage to house door does not have seals installed

-Seal exterior gas line to siding penetration

-Sod, splash pads and sump pump extension are not installed

-Driveway final inspection is not completed -Sidewalks final inspection is not completed

-Plot plan inspection could not be done because of final grading is not

completed

**Comments:**