## CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

## **DEVSERVICES.CITYOFLS.NET**

## **Inspection Summary**

Permit #: PRRES20242627

Address: 3509 SE CORBIN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date:

Occupancy Inspection - Codes Kyle Beard Failed Monday, March 03,

Residential 2025

Corrective Action Required:

2 Miscellaneous Garage to house door will not properly close tight

Correction Fire block gaps in sheet rock above garage overhead doors

Final grading is not complete in areas for plot plan inspection

Gutters are not installed

Sod and splash pads are not installed Sump pump extension is not installed

Driveway final is not finalized Sidewalk final in not finalized

Comments: