

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20244689
Address: 25 NW TUDOR RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control Inspection	John Jackson	Failed	Tuesday, March 04, 2025

Informational:	
1 Misc	1/31/25 Friday JMJ Erosion control silt fencing was installed last week around perimeter.
Corrective Action Required:	
2 Misc	03/04/25 JMJ Straw waddles need to be installed as per Lee's Summit specification. The storm box on the down hill side of project has no straw waddle protection.

Comments: