

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20242465  
Address: 2759 SW 12TH TER, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Shawn Hoffman	Failed	Tuesday, March 04, 2025

Corrective Action Required:

1	Misc	- Pending sidewalk inspection - Raise water meter pit to grade - Land sewer trace wire to greade
---	------	--------------------------------------------------------------------------------------------------------

**Comments:**