

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20230994
Address: 1021 SE HAMBLER RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control Inspection Residential	Bobby Richest	Partial	Tuesday, March 04, 2025

Corrective Action Required:

1	Misc	-Install gravel filter at site entrance and clean mud from streets. No further inspections will be performed until in compliance
		1-2-25 BR Contractor installed gravel on south entrance of site and clean up mud off street.
		2-3-25 BR Erosion control is up and working order.
		2-17-25 BR Erosion control is up and working order.
		2-28-25 BR Silt fence has several cut and rips in silt fence around entire property. Need to repair silt fence control erosion properly.
		3-4-25 BR Erosion control is up and working order.

Comments: