

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20243024  
Address: 3217 SW SADDLEBRED TER, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Mitchell Schwarz	Failed	Wednesday, February 26, 2025

Corrective Action Required:

1	Misc	-multiple holes throughout entire home drilled in joists closer than 2" to one another(all holes not address provide engineer report for fix uploaded to portal and onsite) Last item on engineer reprint addresses
---	------	--

**Comments:**