

Hydraulic Summary

Job Number: NC-1461
Report Description: Ordinary Group II

Job

Job Number
NC-1461

Job Name:
Flex Spaces

Address 1
60 SE Thompson Dr

Address 2
Lee's Summit, MO 64081

Address 3

Designer

State Certification/License Number

AHJ
LS Codes

Job Site/Building
Ord II Haz - Shell

Drawing Name
FlexSpace-B-City-QR-REV-02-27-2025

System

Most Demanding Sprinkler Data
5.6 K-Factor 23.60 at 17.760

Hose Allowance At Source
0.00

Additional Hose Supplies

Node Flow(gpm)
Hydrant At Node 12 250.00

Remote Area(s)

Occupancy
Ordinary Group II

Density
0.20gpm/ft²

Area of Application
1069ft² (Actual 1173ft²)

Number Of Sprinklers Calculated
10

Number Of Nozzles Calculated
0

Coverage Per Sprinkler
120ft²

Total Hose Streams
250.00

System Flow Demand
500.98

Maximum Pressure Unbalance In Loops
0.000

Maximum Velocity Above Ground
19.43 between nodes 381 and 383

Maximum Velocity Under Ground
5.19 between nodes 1 and 8

Volume capacity of Wet Pipes
537.07gal

Total Water Required (Including Hose Allowance)
500.98

Volume capacity of Dry Pipes



Supplies

Node	Name	Hose Flow (gpm)	Static (psi)	Residual (psi) @	Flow (gpm)	Available (psi) @	Total Demand (gpm)	Required (psi)	Safety Margin (psi)
1	Water Supply		82.000	40.000	1250.00	74.262	500.98	55.661	18.601

Contractor

Contractor Number
01

Name of Contractor:
Alliance Fire Protection

Address 1
130 W 9th Ave #101

Address 2
North Kansas City, MO 64116

City

Contact Name

Contact Title


Phone
913-888-0647

FAX
913-888-0618

E-mail

Web-Site

Water Supply at Node 1



Hydraulic Graph

Water Supply at Node 1

Static: Pressure
82.000

Residual: Pressure
40.000 @ 1250.00

Available Pressure at (?|b|Test|Time)
74.262 @ 500.98

System Demand
55.661 @ 500.98

System Demand (Including Hose Allowance at Source)
55.661 @ 500.98

Summary Of Outflowing Devices

	Device		Actual Flow (gpm)	Minimum Flow (gpm)	K-Factor (K)	Pressure (psi)
	Hydrant	12	250.00	250.00	0	52.547
	Sprinkler	623	26.62	23.60	5.6	22.595
	Sprinkler	624	26.56	23.60	5.6	22.494
	Sprinkler	656	24.74	23.60	5.6	19.524
	Sprinkler	657	24.69	23.60	5.6	19.436
	Sprinkler	679	26.82	24.00	5.6	22.945
	Sprinkler	680	23.89	23.60	5.6	18.204
	Sprinkler	681	23.84	23.60	5.6	18.121
	Sprinkler	711	26.56	24.00	5.6	22.496
	Sprinkler	712	23.65	23.60	5.6	17.841
⇒	Sprinkler	713	23.60	23.60	5.6	17.760
⇒	Most Demanding Sprinkler Data					

Node Analysis

Node	Elevation(Foot)	Fittings	Pressure(psi)	Discharge(gpm)
1	4'-0	S	55.661	500.98
12	4'-0	Hyd	52.547	250.00
623	16'-6	Spr(-22.595)	22.595	26.62
624	16'-6	Spr(-22.494)	22.494	26.56
656	16'-6	Spr(-19.524)	19.524	24.74
657	16'-6	Spr(-19.436)	19.436	24.69
679	16'-6	Spr(-22.945)	22.945	26.82
680	16'-6	Spr(-18.204)	18.204	23.89
681	16'-6	Spr(-18.121)	18.121	23.84
711	16'-6	Spr(-22.496)	22.496	26.56
712	16'-6	Spr(-17.841)	17.841	23.65
713	16'-6	Spr(-17.760)	17.760	23.60
8	-5'-0	T(47'-3½)	56.600	
203	1'-2		53.850	
377	15'-6	PO(7'-5)	28.527	
381	15'-6	PO(7'-5)	28.086	
383	16'-6	PO(7'-5)	23.169	
384	15'-6	PO(7'-5)	27.964	
386	16'-6	PO(7'-5)	23.066	

Hydraulic Analysis

Job Number: NC-1461
Report Description: Ordinary Group II

Pipe Type Downstream Upstream	Diameter Elevation	Flow Discharge	Velocity K-Factor	HWC Pt	Pn	Friction Loss Fittings	Length Eq. Length Total Length	Pressure Summary
..... Route 1								
BL	1.4420	23.60	4.64	120		0.037530	9'-7½	Pf 0.361
713	16'-6	23.60	5.6	17.760		Sprinkler		Pe
681	16'-6			18.121			9'-7½	Pv
BL	1.4420	47.44	9.32	120		0.136565	9'-7½	Pf 1.314
681	16'-6	23.84	5.6	18.121		Sprinkler		Pe
657	16'-6			19.436			9'-7½	Pv
BL	1.4420	72.13	14.17	120		0.296465	4'-10	Pf 3.630
657	16'-6	24.69	5.6	19.436		Sprinkler,	7'-5	Pe
386	16'-6			23.066		PO(7'-5)	12'-3	Pv
RN	1.4420	98.69	19.39	120		0.529506	1'-0	Pf 4.465
386	16'-6	26.56		23.066		Flow (q) from Route 4	7'-5	Pe 0.434
384	15'-6			27.964		PO(7'-5)	8'-5	Pv
CM	3.2600	98.69	3.79	120		0.009969	12'-3	Pf 0.122
384	15'-6			27.964				Pe
381	15'-6			28.086			12'-3	Pv
CM	3.2600	197.60	7.60	120		0.036014	12'-3	Pf 0.441
381	15'-6	98.91		28.086		Flow (q) from Route 2		Pe
377	15'-6			28.527			12'-3	Pv
CM	3.2600	250.98	9.65	120		0.056056	287'-3	Pf 19.115
377	15'-6	53.39		28.527		Flow (q) from Route 3	53'-9	Pe 6.207
203	1'-2			53.850		2E(9'-5), f(-0.000), BV(13'-5½), sCV(21'-6)	341'-0	Pv
UG	6.2800	250.98	2.60	140		0.001730	18'-5½	Pf 0.070
203	1'-2			53.850			22'-1	Pe 2.681
8	-5'-0			56.600		E(22'-1)	40'-6½	Pv
UG	6.2800	500.98	5.19	140		0.006215	55'-8	Pf 2.953
8	-5'-0	250.00		56.600		Flow (q) from Route 6	22'-1	Pe -3.893
1	4'-0			55.661		BFP(-2.470), E(22'-1), S	77'-8½	Pv
..... Route 2								
BL	1.4420	23.65	4.65	120		0.037688	9'-7½	Pf 0.363
712	16'-6	23.65	5.6	17.841		Sprinkler		Pe
680	16'-6			18.204			9'-7½	Pv
BL	1.4420	47.55	9.34	120		0.137141	9'-7½	Pf 1.320
680	16'-6	23.89	5.6	18.204		Sprinkler		Pe
656	16'-6			19.524			9'-7½	Pv
BL	1.4420	72.29	14.20	120		0.297713	4'-10	Pf 3.645
656	16'-6	24.74	5.6	19.524		Sprinkler,	7'-5	Pe
383	16'-6			23.169		PO(7'-5)	12'-3	Pv
RN	1.4420	98.91	19.43	120		0.531727	1'-0	Pf 4.483
383	16'-6	26.62		23.169		Flow (q) from Route 5	7'-5	Pe 0.434
381	15'-6			28.086		PO(7'-5)	8'-5	Pv
..... Route 3								
BL	1.4420	26.56	5.22	120		0.046702	9'-7½	Pf 0.450
711	16'-6	26.56	5.6	22.496		Sprinkler		Pe
679	16'-6			22.945			9'-7½	Pv
BL	1.4420	53.39	10.49	120		0.169912	15'-5½	Pf 5.149
679	16'-6	26.82	5.6	22.945		Sprinkler,	14'-10½	Pe 0.434
377	15'-6			28.527		2PO(7'-5)	30'-3½	Pv
..... Route 4								
BL	1.4420	26.56	5.22	120		0.046699	4'-10	Pf 0.572
624	16'-6	26.56	5.6	22.494		Sprinkler,	7'-5	Pe
386	16'-6			23.066		PO(7'-5)	12'-3	Pv
..... Route 5								
BL	1.4420	26.62	5.23	120		0.046893	4'-10	Pf 0.574
623	16'-6	26.62	5.6	22.595		Sprinkler,	7'-5	Pe
383	16'-6			23.169		PO(7'-5)	12'-3	Pv
..... Route 6								
UG	6.2800	250.00	2.59	140		0.001718	19'-0	Pf 0.152
12	4'-0	250.00		52.547		Hydrant,	69'-4	Pe 3.902
8	-5'-0			56.600		E(22'-1), T(47'-3½)	88'-4	Pv

Equivalent Pipe Lengths of Valves and Fittings (C=120 only)

C Value Multiplier

$$\left(\frac{\text{Actual Inside Diameter}}{\text{Schedule 40 Steel Pipe Inside Diameter}} \right)^{4.87} = \text{Factor}$$

Value Of C	100	130	140	150
Multiplying Factor	0.713	1.16	1.33	1.51

Hydraulic Analysis

Job Number: NC-1461

Report Description: Ordinary Group II

Pipe Type	Diameter	Flow	Velocity	HWC		Friction Loss	Length	Pressure
Downstream	Elevation	Discharge	K-Factor	Pt	Pn	Fittings	Eq. Length	Summary
Upstream							Total Length	
Pipe Type Legend			Units Legend			Fittings Legend		
AO	Arm-Over	Diameter	Inch			ALV	Alarm Valve	
BL	Branch Line	Elevation	Foot			AngV	Angle Valve	
CM	Cross Main	Flow	gpm			b	Bushing	
DN	Drain	Discharge	gpm			BaIV	Ball Valve	
DR	Drop	Velocity	fps			BFP	Backflow Preventer	
DY	Dynamic	Pressure	psi			BV	Butterfly Valve	
FM	Feed Main	Length	Foot			C	Cross Flow Turn 90°	
FR	Feed Riser	Friction Loss	psi/Foot			cplg	Coupling	
MS	Miscellaneous	HWC	Hazen-Williams Constant			Cr	Cross Run	
OR	Outrigger	Pt	Total pressure at a point in a pipe			CV	Check Valve	
RN	Riser Nipple	Pn	Normal pressure at a point in a pipe			DeIV	Deluge Valve	
SN	Swing Nipple	Pf	Pressure loss due to friction between points			DPV	Dry Pipe Valve	
SP	Sprig	Pe	Pressure due to elevation difference between indicated points			E	90° Elbow	
ST	Stand Pipe	Pv	Velocity pressure at a point in a pipe			EE	45° Elbow	
UG	Underground					Ee1	11¼° Elbow	
						Ee2	22½° Elbow	
						f	Flow Device	
						fd	Flex Drop	
						FDC	Fire Department Connection	
						fE	90° FireLock(TM) Elbow	
						fEE	45° FireLock(TM) Elbow	
						flg	Flange	
						FN	Floating Node	
						fT	FireLock(TM) Tee	
						g	Gauge	
						GloV	Globe Valve	
						GV	Gate Valve	
						Ho	Hose	
						Hose	Hose	
						HV	Hose Valve	
						Hyd	Hydrant	
						LtE	Long Turn Elbow	
						mecT	Mechanical Tee	
						Noz	Nozzle	
						P1	Pump In	
						P2	Pump Out	
						PIV	Post Indicating Valve	
						PO	Pipe Outlet	
						PrV	Pressure Relief Valve	
						PRV	Pressure Reducing Valve	
						red	Reducer/Adapter	
						S	Supply	
						sCV	Swing Check Valve	
						SFx	Seismic Flex	
						Spr	Sprinkler	
						St	Strainer	
						T	Tee Flow Turn 90°	
						Tr	Tee Run	
						U	Union	
						WirF	Wirsbo	
						WMV	Water Meter Valve	
						Z	Cap	

Flow Diagram (Current View)

