

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20241727
Address: 2813 SW HEARTLAND RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Failed	Thursday, March 06, 2025

Corrective Action Required:

1 Misc

- sod
- will check water meter at time of sod(ensure 14"-18" from top of meter to top of well ring lid)
- provide spark ring at outlet above fireplace
- paint gas line at deck
- re-establish erosion control at rear of lot
- ensure all exterior penetrations are sealed

Comments: