CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20244021

Address: 1113 SW FIORD DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date:

Occupancy Inspection - Codes Shawn Hoffman Failed Thursday, March 06,

Residential 2025

Corrective Action Required:

1 Misc 1113 sw fjord

- sidewalk and driveway inspection pending
- Final grading and sod
- Pull forms from driveway and sidewalk
- Sump discharge to be 36" away from foundation
- Provide splash pads to divert water to 36" away from foundation
- Land sewer trace wire at gradeWater meter pit at grade
- Provide landing for deck stairs
- Maintain 6" clearance from siding to grade at back of house
- Owners entry to be self closing and latch
- Provide landing at basement sliding door
- Secondary lock at basement sliding door not operating

Comments: