

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #: PRRES20242723
Address: 1054 SW FIORD DR, LEES SUMMIT, MO 64081
Inspected On: Thursday, March 06, 2025
Inspected By: Development Center
Expiration Date:

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Shawn Hoffman	Ready for Temp CO	Thursday, January 23, 2025

Corrective Action Required:

- | | | |
|---|------|---|
| 1 | Misc | <ul style="list-style-type: none">- Be aware of 6" clearance of siding to grade at back of house- Outside outlets to be weather resistant- Final grading and sod- Provide splash pads- Land sewer trace wire to grade- Sump discharge to be 36" away from foundation |
|---|------|---|

Comments: