

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20244614
Address: 3437 SE CORBIN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sidewalk Inspection	Jamie Simerly	Passed	Thursday, March 06, 2025

Informational:
1 Misc 02/26/2025 - Jamie S, SW is compacted, and forms are sloped to city standards, North panel will be out of compliance for storm manhole, approved to pour
03-06-25 Jamie S, SW slopes are within city standards

Comments: