#### CITY OF LEE'S SUMMIT

Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816) 969-1200 FAX (816) 969-1201

# **STOP WORK ORDER**

## ANY UNAUTHORIZED PERSON REMOVING THIS NOTICE WILL BE PROSECUTED

Permit #: PRRES20243620

Address: 3216 SW ARBORIDGE CIR, LEES SUMMIT, MO 64082

Any person who shall continue work after having been served with a stop work order, except such work as that person is directed to perform to remove a violation or unsafe condition, shall be subject to penalties as prescribed by law.

Inspection: Outcome: Date:

**Erosion Control** Dustin Agcopra Failed - Stop Work Thursday, March 06, 2025

**Inspection Residential** 

Corrective Action Required

DCM1 ESC REQUIRED NO EROSION CONTROL REQUIRED. NO FURTHER INSPECTIONS WILL

FURTHER INSP

BE PERFORMED UNTIL EROSION CONTROL IS INSTALLED AND IN

COMPLIANCE.

Corrective Action Required

DAY

2 DCM3 ESC REQUIRED 2 1-22-25 Dustin A, no erosion control in place EROSION CONTROL

REQUIRED. EROSION CONTROL SHALL BE IN COMPLIANCE

WITHIN TWO BUSINESS DAYS.

1-22-25 Dustin A, Straw waddles were installed. Erosion control

must be maintained. Pass

Corrective Action Required

DAY

3 DCM3 ESC REQUIRED 2 3-3-25 Dustin A, SW needs cleaned from silt. EROSION

CONTROL REQUIRED. EROSION CONTROL SHALL BE IN

COMPLIANCE WITHIN TWO BUSINESS DAYS.

3-6-25 Dustin, has not been addressed

#### **Comments:**

### CITY OF LEE'S SUMMIT

Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816) 969-1200 FAX (816) 969-1201