

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20245377
Address: 2222 SW HEARTLAND CT, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Driveway Inspection	Devon Perry	Passed	Thursday, March 06, 2025

Informational:

1 Misc

2-28-25 Dustin A, DW was formed and compacted. Informed super that expansion joint needed where approach meets curb and SW. Approved to pour

3-6-25 DP. DW was poured, forms have been removed. Cross slopes are in compliance. Passed.

Comments: