

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20245377  
Address: 2222 SW HEARTLAND CT, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Driveway Inspection</b>	Devon Perry	Passed	Thursday, March 06, 2025

Informational:

1 Misc

2-28-25 Dustin A, DW was formed and compacted. Informed super that expansion joint needed where approach meets curb and SW. Approved to pour

3-6-25 DP. DW was poured, forms have been removed. Cross slopes are in compliance. Passed.

**Comments:**