

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20242541
Address: 3929 SW FLINTROCK DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Driveway Inspection	Jamie Simerly	Failed	Thursday, March 06, 2025

Informational:
1 Misc 2-27-25 Dustin A, Dw is formed and compacted. Approved to pour
3-6-25 Jamie S, DW slopes are within city compliance, forms need to be removed before approval. Call in driveway inspection back in once forms are pulled.

Comments: