

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRSUBD20244689  
Address: 25 NW TUDOR RD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Erosion Control Inspection</b>	John Jackson	Failed	Thursday, March 06, 2025

Informational:

1	Misc	1/31/25 Friday JMJ Erosion control silt fencing was installed last week around perimeter.
---	------	--

Corrective Action Required:

2	Misc	03/04/25 JMJ Straw waddles need to be installed as per Lee's Summit specification. The storm box on the down hill side of project has no straw waddle protection.  03/06/25 JMJ (Supervisor Shawn Bartholomew/ Cityscape) Contractor will have all straw waddles for storm boxes onsite will be installed by tomorrow as per Lee's Summit specification.
---	------	--

**Comments:**