



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION

220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Certificate of Occupancy

Permit #: PRCOM20100137
Address: 1255 NE DOUGLAS ST, LEES SUMMIT, MO 64086
Inspected On: Friday, December 09, 2011
Inspected By: John BornsJohn BornsJennifer Thompson

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Hood/Duct Inspection	John Borns	Passed	Friday, December 09, 2011
Occupancy Inspection - Codes Commercial	John Borns	Full C of O	Friday, December 09, 2011
Occupancy Inspection - Planning	Jennifer Thompson	Passed	Friday, December 09, 2011

Comments: NEBBS-CERTIFIED GREASE HOOD PERFORMANCE TEST REPORT NOT RECEIVED. HVAC CONTRACTOR WAS ALLOWED TO SELF-CERTIFY PERFORMANCE TESTS PER MARK DUNNING.