CITY OF LEE'S SUMMIT

Development Services Department 220 SE Green Street Lee's Summit, MO 64063 FAX (816) 969-1201 (816) 969-1200

Temporary Certificate of Occupancy

Permit #: PRRES20242627

Address: 3509 SE CORBIN DR, LEES SUMMIT, MO 64082

Inspected On: Monday, March 10, 2025 **Inspected By: Development Center**

Expiration Date:

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date:

Occupancy Inspection - Codes Ready for Temp CO Khanh Nguyen Thursday, March 06, 2025

Residential

Corrective Action Required:

Miscellaneous Final grading is not complete in areas for plot plan inspection

> Correction Sod and splash pads are not installed Sump pump extension is not installed

> > Driveway final is not finalized Sidewalk final in not finalized

Comments: