

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20245538  
Address: 2770 SW 11TH TER, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Shawn Hoffman	Failed	Monday, March 10, 2025

Corrective Action Required:

2	Misc	<ul style="list-style-type: none"><li>- Provide joists hanger to joist with no bearing kitchen and pantry to triple LVL</li><li>- Protect wiring within 6' of attic access second floor</li><li>- Repair gravel filter at lot access</li></ul>
---	------	--

**Comments:**