

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20246187
Address: 2765 SW 11TH ST, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Shawn Hoffman	Failed	Monday, March 10, 2025

Informational:

1	Miscellaneous Correction	Exterior garage PFH sheathing and front porch truss tie downs passed and are okay to cover
---	--------------------------	--

This is a partial pass only

Corrective Action Required:

2	Misc	<ul style="list-style-type: none">- In pantry, fire block soffit at HVAC chase and garage wall- Floor joist hangers missing nails in great room- Minimum of 3 studs on exterior corners, basement South corner- No gauge on Gas line for inspection
---	------	--

Comments: