

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20236204
Address: 2361 SW RIVER TRAIL RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Ready for Temp CO	Monday, March 10, 2025

Corrective Action Required:

1	Misc	-final grade and sod -as graded plot plan -address pending sidewalk inspection -splash blocks and sump pump discharge to extend 36" from foundation -will check water meter at time of final grade and sod (ensure 14"-18" from top of meter to well lid ring)
---	------	--

Comments: