

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20231105

Address: 800 NW WARD RD, Unit:IR, LEES SUMMIT, MO 64086800 NW WARD RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Miscellaneous Inspection	Khanh Nguyen	Partial	Monday, March 10, 2025

Corrective Action Required:

1	Misc	Pre final for units only Building D: ****4th floor -Clarify rating for glazing in office window -Install threshold at stairway door -Mechanical/storage room not ready 1438-Receptacle at bathroom is not GFCI protected 1443-Uncover sprinkler heads, island receptacle not working 144-exterior incomplete Pre-final walkthrough for Bdg 1, Seg D, 2nd fl: 1231: -Range anti-tipping device -Secure dishwasher loop drain -No power to patio receptacle -Washer breaker not afci 1232-ok 1234:
---	------	--

- Bathroom receptacle not gfci
- Loop up dishwasher drain
- Protect sprinkler head above closet shelf
- Washer breaker not afci

1236-ok

1237:

- Bathroom receptacle not gfci

1238-ok

Comments: