

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20242858

Address: 1426 SW WINTHROP TER, LEES SUMMIT, MO 64081
1424 SW WINTHROP TER, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	Mitchell Schwarz	Passed	Tuesday, March 11, 2025

Informational:

1 MISC

-Attic fire separation wall and basement floor joist-OK
-separation walls okay to cover

Comments: