## CITY OF LEE'S SUMMIT

Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816) 969-1200 FAX (816) 969-1201

## Temporary Certificate of Occupancy

Permit #: PRRES20242647

Address: 3224 SW ARBORIDGE CIR, LEES SUMMIT, MO 64082

Inspected On: Tuesday, March 11, 2025
Inspected By: Development Center
Expiration Date: 1/11/2025 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until** approved.

Inspection: Outcome: Date:

Occupancy Inspection - Codes Mitchell Schwarz Ready for Temp CO Thursday, December

Residential

Corrective Action Required:

1 Misc -final grade and sod

-install gutters

-splash blocks and sump pump discharge to extend 36" from foundation

12, 2024

Comments: