

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20243123

Address: 3719 SW KNOXVILLE CT, LEES SUMMIT, MO 640823717 SW KNOXVILLE CT, LEES SUMMIT, MO
64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---|------------------|-----------|---------------------------|
| Occupancy Inspection - Codes Residential | Mitchell Schwarz | Not Ready | Wednesday, March 12, 2025 |

Corrective Action Required:

1 Misc

Not a complete list. Inspection denied.

- address pending driveway sidewalk and pier inspection
- missing guard rail at front stoop
- deck not completed
- erosion control not in compliance

Comments: