

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20246296  
Address: 2531 NE WOODLAND OAK CIR, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Underslab Plumbing Inspection - Residential</b>	Khanh Nguyen	Not Ready	Wednesday, March 12, 2025

Corrective Action Required:

1	Misc	Complete the drain tile installation. Connect the interior drain tile to the exterior drain tile
		Provide gravel bed at driveway.
		<b>**3/12-Another not-ready fee assessed</b>

**Comments:**