

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20231204
Address: 2951 SE SHENANDOAH DR, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	Khanh Nguyen	Failed	Wednesday, March 12, 2025

Corrective Action Required:

1	Misc	Upper floor: -All except guest suite, restrooms, work/break room, leasing office Basement-OK to close ceiling around fire-rated walls Above restrooms and adjacent space: -Support and securely fasten all NM cables per code -Protect NM cables near access openings to mechanical units -Support ceiling grid
---	------	---

Comments: