



CITY OF LEE'S SUMMIT  
CODES ADMINISTRATION  
220 SE GREEN ST.  
P.O.BOX 1600

PHONE:  
816-969-1200

FAX:  
816-969-1201

## Inspection Summary

---

Permit #: PRCOM20112915, Building Permit - Commercial  
Address: 80 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>In-wall Inspection</b>	John Borns	Partial	Tuesday, December 13, 2011

Partial Correction  
1 MISC

OK TO COVER WHEN READY WALL FRAMING AND IN-WALL  
SYSTEMS AT SPACES: 81; 82 S,E,W,; 162 N; 74; 75; 76; 77; 78;  
78B; 79; 79B; 80;

**Comments: BEFORE COVERING ENSURE COPPER PIPING PENETRATIONS OF STEEL FRAMING ARE ISOLATED/PROTECTED PER IPC. ONE LOCATION WHERE WALL FRAMING MUST BE RESTORED WHERE PENETRATED BY HVAC DUCT.**