

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #: PRRES20240373
Address: 3209 SW ARBOR TREE DR, LEES SUMMIT, MO 64082
Inspected On: Thursday, March 13, 2025
Inspected By: Development Center
Expiration Date: 2/15/2025 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Ready for Temp CO	Wednesday, January 08, 2025

Corrective Action Required:

1	Misc	-uncover covered water meter -final grade and sod -splash blocks and sump pump discharge to extend 36" from foundation
---	------	--

Occupancy Inspection - Codes Residential	Mitchell Schwarz	Ready for Temp CO	Friday, December 06, 2024
---	------------------	-------------------	---------------------------

Corrective Action Required:

1	Misc	-uncover covered water meter -final grade and sod -splash blocks and sump pump discharge to extend 36" from foundation
---	------	--

Comments: