

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #:	PRRES20241136
Address:	3237 SW ARBOR TREE DR, LEES SUMMIT, MO 64082
Inspected On:	Thursday, March 13, 2025
Inspected By:	Development Center
Expiration Date:	4/12/2025 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Ready for Temp CO	Thursday, September 12, 2024
Corrective Action Required:			
1 Misc	-pay all fees -final grade and sod -splash blocks and sump pump discharge to extend 36" from foundation -identify sewer tracer wire -will check water meter at time of final grade and sod		

Comments: