

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20233629
Address: 3215 SW ENOCH ST, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Failed	Thursday, March 13, 2025

Corrective Action Required:

2	Misc	-seal all penetrations in return air joist spaces -fireblock furr downs see basement bath/ closet -fireblock wall to ceiling furr down at stairs -fireblock beam ends in basement
---	------	--

Comments: