

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #: PRRES20241515
Address: 1605 SW BUCKTHORN ST, LEES SUMMIT, MO 64082
Inspected On: Thursday, March 13, 2025
Inspected By: Development Center
Expiration Date: 11/21/2024 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Ready for Temp CO	Tuesday, October 22, 2024

Corrective Action Required:

1	Misc	-pay all fees -sod -splash blocks and sump pump discharge to extend 36" from foundation -uncover covered water meter Bring water meter well ring lid to grade(ensure water meter is 14 to 18 inches from top of meter to well, lid ring -identify sewer tracer wire
---	------	---

Comments: