

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20245948
Address: 1071 SW FIORD DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Shawn Hoffman	Failed	Thursday, March 13, 2025

Informational:

1	Misc	Garage portal framing only-OK
---	------	-------------------------------

Corrective Action Required:

2	Miscellaneous Correction	<ul style="list-style-type: none">- Missing nails in LIB at bedroom 5- Fire block penetration at top of HVAC chase in pantry- Provide hanger for truss at single bay garage at I- beam- Missing truss hold downs at primary bedroom closet and upstairs laundry- Missing truss hanger laundry near toilet
---	--------------------------	---

Comments: