CITY OF LEE'S SUMMIT

Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #: PRRES20240585

Address: 3232 SW ARBOR SOUND DR, LEES SUMMIT, MO 64082

Inspected On: Thursday, March 13, 2025

Inspected By: Development Center
Expiration Date: 4/12/2025 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection: Inspector: Outcome: Date:

Occupancy Inspection - Codes Mitchell Schwarz Ready for Temp CO Thursday, August 15,

Residential

Corrective Action Required:

1 Misc Pay all fees

-address pending driveway inspection-address pending pier inspection-provide as graded plot plan

-final grade and sod

-will check water meter at time of final grade

-splash blocks and sump pump discharge to extend 36" from foundation

2024

-seal all exter penetrations and top of a/c disconnect

Comments: