CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #:	PRRES20241005
Address:	1628 SW ARBORWAY TER, LEES SUMMIT, MO 64082
Inspected On:	Thursday, March 13, 2025
Inspected By:	Development Center
Expiration Date:	4/11/2025 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential Corrective Action Required:	Mitchell Schwarz	Ready for Temp CO	Wednesday, September 11, 2024
1 Misc	 -address pending driveway inspection -address pending sidewalk inspection -address pending pier inspection -pay all fees -provide as graded plot plan -final grade and sod -will check water meter at time of final grade and sod -sump pump and splash blocks to extend 36" from foundation -obtain issued lawn irrigation permit 		

Comments: