

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20232768  
Address: 810 NW WARD RD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Commercial</b>	Robb Popp	Partial	Thursday, March 13, 2025

Corrective Action Required:

1 STAIR TOWER 1 complete

Corrective Action Required:

2 STAIR TOWER 2 complete

Corrective Action Required:

3 STAIR TOWER 3 complete

Corrective Action Required:

4 FIRST FLOOR Building F  
Complete except as noted:  
157-NOT READY  
389-Walls only ok-complete meps at ceiling and seal dead space

Building G:  
complete

Building H:  
complete

Building J:  
Seal dead spaces throughout  
108-complete dwv  
Mechanical room walls only

Corrective Action Required:

5

SECOND FLOOR

Building F:

-Units and corridor complete

Building G:

-Units and corridor complete

Building H:

Units and corridor complete

Building J:

complete

Corrective Action Required:

6

THIRD FLOOR

\*Building F

-Units and corridor approved

Building G:

-Units and corridor approved

Building H:

-Units and corridor approved

Building J:

-Units and corridor approved

Corrective Action Required:

7

FOURTH FLOOR

\*Building F

Complete

\*Building G:

complete

Building H:

Complete

Building J:

Complete

Corrective Action Required:

8

ELEVATOR 1

Interior framing ok all floors

Corrective Action Required:

9

ELEVATOR 2

Elevator in G:

Framing approved

Corrective Action Required:

10

LOWER LEVEL

H, I, J approved

-Exterior garage light metal boxes-all bonded

**Comments:**