CITY OF LEE'S SUMMIT

Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #: PRRES20242368

Address: 1629 SW ARBORWAY TER, LEES SUMMIT, MO 64082

Inspected On: Thursday, March 13, 2025

Inspected By: Development Center
Expiration Date: 1/19/2025 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Occupancy Inspection - Codes Mitchell Schwarz Ready for Temp CO Friday, December 20,

Residential

Corrective Action Required:

1 Misc -final grade and sod

-splash blocks and sump pump discharge to extend 36" from foundation

2024

Comments: