

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20245198
Address: 2012 NE BLUESTONE DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Final Inspection - Residential	Khanh Nguyen	Failed	Thursday, March 13, 2025

Corrective Action Required:

1	Misc	-Module cannot be located outside bedroom window -Secure raceway per code; tighten raceway connections to enclosure -Bond the metal raceway with bonding bushing -Label panel per plan
---	------	---

Comments: