

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816) 969-1200 FAX (816) 969-1201

# Temporary Certificate of Occupancy

---

**Permit #:** PRRES20242328  
**Address:** 3505 SE CORBIN DR, LEES SUMMIT, MO 64082  
**Inspected On:** Thursday, March 13, 2025  
**Inspected By:** Development Center  
**Expiration Date:**

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Shawn Hoffman	Ready for Temp CO	Thursday, March 13, 2025

**Corrective Action Required:**

- |   |                          |  |
|---|--------------------------|--|
| 1 | Miscellaneous Correction | <ul style="list-style-type: none"><li>- Land sewer trace wire to grade</li><li>- Sump discharge to be 36" away from foundation</li><li>- Install splash pads</li><li>- Final grading and sod</li><br/><li>- Lower water meter and pit to grade</li></ul> |
|---|--------------------------|--|

**Comments:**