

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20241886  
Address: 251 NE ALURA WAY, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Footing Inspection - Commercial</b>	Khanh Nguyen	Partial	Thursday, March 13, 2025

Informational:  
1 Misc

Exterior footing:

- Spread footing from AC/7 to AC/1.1 to J/1 to J/5
- Rest of footing, except at vehicle entrance from A/17 to D/18

Interior footing:

- Spread footing from AC/2 to A/1.1
- Elevator pad and step footing

**\*\*Pump out water before pouring. Ok to pour concrete pending approval from the on site engineer**

**Comments:**