

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20245515  
Address: 2624 NE WOODLAND OAK DR, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:                                       | Inspector:   | Outcome: | Date:                  |
|---|--------------|----------|------------------------|
| <b>Erosion Control Inspection<br/>Residential</b> | Khanh Nguyen | Failed   | Friday, March 14, 2025 |

| Corrective Action Required: |   |
|-----------------------------|---|
| 1                           | DCM1 ESC<br>REQUIRED NO<br>FURTHER INSP   |
|                             | EROSION CONTROL REQUIRED FOR THE PILE OF DIRT ON ADJACENT LOT.<br><br>NO FURTHER INSPECTIONS WILL BE PERFORMED UNTIL EROSION CONTROL IS<br>INSTALLED AND IN COMPLIANCE. |

**Comments:**