

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20245263
Address: 2626 SW FIREFLY LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Failed	Friday, March 14, 2025

Corrective Action Required:

1	Misc	-pay all fees -stairs at rear patio greater 3/8" difference in rise. -provide spark rings at outlets in kitchen where required -seal penetrations at top of wall at garage doors -missing AFCI and GFCI protection for multiple circuits -
---	------	---

Comments: